# Low Differential Pressure Sensor Series PSE550/300



16-3-33

Courtesy of Steven Engineering, Inc - (800) 258-9200 - sales@steveneng.com - www.stevenengineering.com

# 

# Low Differential Pressure Sensor Series PSE550

How to Order







Note 1) Current output type cannot be connected to the Series PSE300. Note 2) The connector is unassembled in the factory but is included with the shipment.

#### Option 1 (Bracket)



Note) The bracket is unassembled in the factory, but is included with the shipment.

#### **Option/Part No.**

Description	Part no.	Note
Bracket	ZS-30-A	With M3 x 5L (2 pcs.)
Connector for PSE300	ZS-28-C	1 pc.

#### Specifications

Model		PSE550	PSE550-28		
Rated differential pressure range		0 to 2 kPa			
Operating pressure range		-50 to 50 kPa Note)			
Proof	pressure	65 kPa			
Appli	cable fluid	Air/Non-corrosive gas/Non-inflammable gas			
Powe	r supply voltage	12 to 24 VDC ±10%, Ripple (p-p) 10% or less (With power supply polarity protection)			
Curre	ent consumption	15 mA or less —			
Output specification		Analog output 1 to 5 VDC (Within rated differential pressure range) Output impedance: Approx. 1 kΩ	Analog output 4 to 20 mADC (Within rated differential pressure range) Allowable load impedance: $500 \ \Omega$ or less (at 24 VDC) $100 \ \Omega$ or less (at 12 VDC)		
Accuracy (Ambient temperature of 25°C)		±1% F.S. or less			
Linearity		±0.5% F.S. or less			
Repeatability		±0.3% F.S. or less			
Indication light		Orange light is on (When energized)			
e e	Enclosure	IP40			
star	Operating temperature range	Operating: 0 to 50°C, Stored: $-20$ to 70°C (No freezing or condensation)			
esi	Operating humidity range	Operating/Stored: 35 to 85% RH (No condensation)			
al r	Withstand voltage	1000 VAC or more, 50/60 Hz for 1 minute between live parts and case			
Insulation resistance		50 $M\Omega$ or more between live parts and case (at 500 VDC)			
L L L	Vibration resistance	10 to 150 Hz at whichever is smaller of 1.5 mm amplitude or 100 m/s <sup>2</sup> acceleration,			
<u>vir</u>		in X, Y, Z directions, for 2 hours each (De-energized)			
ш Impact resistance		300 m/s <sup>2</sup> in X, Y, Z directions, 3 times each (De-energized)			
Temperature characteristics		±3% F.S. or less (Based on 25°C)			
Port size		ø4.8 (ø4.4 in the end) resin piping			
		(Applicable to I.D. ø4 air tubing)			
Material of wetted parts		Resin pipe: Nylon, Piston area of sensor: Silicon			
Sens	or cable	3-wire oval cable (0.15 mm <sup>2</sup> )	2-wire oval cable (0.15 mm <sup>2</sup> )		
Woight	ht With sensor cable	75	g		
rieig	Without sensor cable	35 g			

Note) Can detect differential pressure from 0 to 2 kPa within the range of -50 to 50 kPa.



# Low Differential Pressure Sensor Series PSE550

#### Analog Output



16-3-35

Courtesy of Steven Engineering, Inc - (800) 258-9200 - sales@steveneng.com - www.stevenengineering.com

Series **PSE Specific Product Precautions 1** 

Be sure to read before handling.

## Pressure Sensor

#### Handling

# 🗥 Warning

- 1. Do not drop, bump, or apply excessive impact while handling. Although the body of the sensor may not be damaged, the inside of the sensor could be damaged and lead to malfunction.
- 2. The tensile strength of the cord is 50 N or less. Applying a greater pulling force to it can cause malfunction. When handling, hold the body of the sensor-do not dangle it from the cord.
- 3. Care should be taken when stripping the outer cable covering as the insulator may be accidentally torn or damaged if incorrectly



Connector

no.

1

2

3

4

Sheath

- 4. Do not use pressure sensors with corrosive and/or flammable gases or liquids.
- 5. Connection of sensor connector
  - Cut the sensor cable as illustrated to the right.
  - · Referring to the table below, insert each lead wire of the cable at the position marked with a number corresponding to the color of the lead wire.
  - · Confirm that the numbers on the connector match the colors of the wires and that the wires are inserted to the bottom. Press Part A by hand for temporary fixing
  - · Press in the central part of Part A vertically with a tool such as pliers.
  - A sensor connector cannot be taken apart for reuse once it is crimped. If the wire arrangement is incorrect or if the wire insertion fails, use a new sensor connector.
  - For connection to SMC Series PSE300 pressure switches. use sensor connectors (ZS-28-C) or econ connectors listed below.



20 mm or more

Wire core color

For PSE300 (ZS-28-C)

Brown (DC (+))

Not connected

Blue (DC (--))

Black (OUT: 1 to 5 V)

Insulator

Part-A

Manufacturer		Part no.	
Sumitomo 3M		37104-3101-000FL	
Tyco Electro	nics AMP	1-1473562-4	
OMRON Co	rporation	XN2A-1430	

- For detailed information about e-con connectors, please consult the manufacturers of the respective connectors.
- . When piping, increase the length of the air tubing to allow for any possible warping, increased tension or moment load or increased tension, etc.
- . In cases where SMC air tubing is not used, make sure the product has similar I.D. accuracy within ø4 ± 0.3 mm.

#### Handling

- · Make sure that the air tubing is firmly inserted to avoid possible disconnection. (Tensile strength is approx. 25 N when being inserted 8 mm.)
- Please consult with SMC if you intend to use with fluids other than air, non-corrosive gas and non-inflammable gas.

#### **Operating Environment**

## 🗥 Warning

- 1. The pressure sensors are CE marked; however, they are not equipped with surge protection against lightening. Lightning surge countermeasures should be applied directly to system components as necessary.
- 2. The pressure sensors do not have an explosion proof rating. Never use pressure sensors in the presence of flammable or explosive gases.

#### **Piping Connection**

#### 🗥 Caution

- · Cut the air tubing vertically.
- · Carefully hold the air tubing and slowly push it into the resin pipe, ensuring that it is inserted by more than 8 mm. For your information, the tensile strength is approx. 25 Resin pipe N when inserted by more than 8 mm



. Insert the low pressure tubing into "Lo" pipe, and the highpressure tubing into "Hi" pipe.

### Controller

Handling

# 🗥 Warning

- 1. Do not drop, bump, or apply excessive impact (100 m/s<sup>2</sup>) while handling. Although the body of the controller case may not be damaged, the inside of the controller could be damaged and cause malfunction.
- 2. The tensile strength of the power supply/output connection cable is 50 N; that of the pressure sensor lead wire with connector is 25 N. Applying a greater pulling force than the applicable specified tensile strength to either of these components can lead to malfunction. When handling, hold the body of the controller.



ISA2 **IS**□ ZSM PF2□ IF

Data

PS <sup>Z</sup>SE<sup>1</sup> ZSP

ZSE□ ISE□

PSE

<sup>z</sup>SE3

Series PSE

**Specific Product Precautions 2** 

Be sure to read before handling.

# Controller

#### Connection

# **Warning**

- 1. Incorrect wiring can damage the switch and cause malfunction or erroneous switch output. Connections should be done while the power is turned off.
- 2. Do not attempt to insert or pull out the pressure sensor or its connector when the power is on. Switch output may malfunction.
- 3. Wire separately from power lines and high voltage lines, avoiding wiring in the same conduit with these lines. Malfunctions may occur due to noise from these other lines.
- 4. If a commercial switching regulator is used, make sure that the F.G. terminal is grounded.

#### **Operating Environment**

# \land Warning

- 1. Our pressure sensor controllers are CE marked; however, they are not equipped with surge protection against lightning. Lightning surge countermeasures should be applied directly to system components as necessary.
- 2. Our pressure sensor controllers do not have an explosion proof rating. Never use pressure sensors in the presence of flammable or explosive gases.

#### Mounting

# **▲** Caution

#### 1. Mounting with bracket

Mount the bracket on the body with two M3 x 5L mounting screws.

Tighten the bracket mounting screws at a tightening torque of 0.5 to 0.7  $\text{N}{\cdot}\text{m}{\cdot}$ 



#### 2. Mounting with panel mount adapter

Secure the panel mount adapter with two M3 x 8L mounting screws.



#### Mounting

#### 3. Panel mount adapter removal

To remove the controller with panel mount adapter from the equipment, remove the two mounting screws, and pull out the controller while pushing the claws outward.

Failure to follow this procedure can cause damage to the controller and panel mount adapter.



#### Wiring

# **A** Caution

#### 1. Connection and removal of sensor connector

- Hold the lever and connector body with two fingers and insert the connector straight into the pin until it is locked with a click sound.
- To remove the connector, pull it out straight while pressing the lever with one finger.



#### 2. Connector pin numbers for power supply/output





Series PSE Specific Product Precautions 3

Be sure to read before handling.

#### Set Differential Pressure Range & Rated Differential Pressure Range

# **A** Caution

#### Set the pressure within the rated differential pressure range.

The set differential pressure range is the range of differential pressure that can be set on the controller. The rated differential pressure range is the range of differential pressure that satisfies the specifications (accuracy, linearity, etc.) of the sensor.

Although it is possible to set a value outside the rated differential pressure range, the specifications will not be guaranteed even if the valve stays within the set differential pressure range.

Canaa		Pressure range				
Senso	or	–2 kPa	0	2 kPa	5 kPa	10 kPa
For low			0	2 kPa		
pressure	C	).2 kPa	2 kPa			

Rated differential pressure range of sensor Set differential pressure range of controller ZSE□ ISE□

PSE

**SMC**