Mission-Critical Paralleling Switchgear

ASCO Power Technologies[™]

ASCO 7000 SERIES Power Control Systems





00

ASCO 7000 SERIES **Power Control Systems**

ASCO 7000 SERIES Power Control Systems (PCS) offer ASCO's widest range of Paralleling Switchgear for mission-critical facilities.

Engineered-to-order from 50+ years of ASCO switchgear experience, these fully customized solutions can parallel utility and emergency power sources for both low and medium voltage applications. ASCO 7000 SERIES PCS can be configured to provide the following capabilities:

- · Parallels up to 32 generators
- · Parallel generators with utility feeds
- Available segmented bus increases availability and speeds generator connection
- Controls up to 128 automatic transfer switches and/or circuit breakers
- · Maximizes use of generator capacity by adding or removing generators according to real-time demand

- Available redundant PLCs and I/O pathways enhance reliability
- · Load prioritization ensures the most important circuits receive power first
- · Manually control addition and shedding of loads and power sources
- Connects Distributed Energy Sources to building power systems

Power Knowledge

La Power Control Systems Feature Comparison

A Power Control Systems <u>Overview</u>

Power Control System Basics



ASCO 7000 SERIES PCS offers the most advanced paralleling switchgear capabilities available today. Every system is custom-engineered to meet specific application requirements. Every customer receives the full benefit of a century of ASCO critical power expertise.

ASCO 7000 SERIES PCS maximizes load distribution and generator efficiency based on real-time capacity and demand. Programmable Logic Controllers supervise sophisticated strategies to manage and optimize onsite energy sources. They also connect load banks to meet loading requirments for dieselpowered generators.



Because every ASCO 7000 SERIES PCS is custom-engineered, facilities benefit from optimization at every level:

- · Optimize use of available power capacity using custom sequences to keep more loads online
- · Manage paralleling of multiple generators, regardless of fuel type or manufacturer
- Switch between distributed energy resources and parallel on-site sources with utility ٠
- · Customize bus configurations to hasten generator connection, increase redundancy, and maximize availability



Power Knowledge

Basic Power Source Synchronization and Paralleling

Get the Most from Power Sources

Parallel Multiple Sources to Provide Greater Capacity

ASCO 7000 SERIES PCS synchronize and connect multiple power sources after comparing voltage, frequency, and phase angle. Bus segmentation enables facilities to connect gensets to priority loads quickly.



Optimize Efficiency by Managing Generator Load Demand

Generator Load Demand maximizes the efficient use of power capacity by adding or removing sources according to demand. It enhances reliability and availability by connecting sufficient power when needed. By operating fewer sources at higher efficiencies, it conserves fuel to reduce emissions and improve sustainability and reduces engine-generator runtime.



Parallel Different Types of Power Sources

Bringing power from a utility feed, generators, and renewables can offer significant operational, sustainability, and cost benefits. More than 50 years ago, ASCO produced its first system for paralleling utility power with generators and we have designed, manufactured, installed, and supported utility paralleling solutions ever since. Benefits include:

- *Utility Load Curtailment* When utilities instruct users to reduce demand, facilities can add alternate distributed power sources instead of shedding load.
- *Peak Shaving* To avoid demand surcharges, facilities can use distributed energy sources to replace a portion of utility power during peak demand periods.
- *Parallel Utility, Generators, and On-Site Renewables* Parallel two or more power sources to enhance reliability, increase sustainability, and reduce energy costs. Support microgrids and integrate renewable power sources for a greener, more sustainable facility.

Add and Keep More Load Online

Bus Optimization

ASCO 7000 SERIES PCS are available with either of two bus optimization capabilities

Standard Bus Optimization evaluates the available capacity of online generators and compares it to the maximum expected value of the next priority load block. If the generation capacity is sufficient, the load block is added to increase utilization.

Dynamic Bus Optimization can further increase generator utilization. When power meters measure discrete loads, a PCS system can more precisely compare capacity and real-time demand. This approach puts the most load online and maximizes generator utilization.



Priority Pass-Along

ASCO 7000 SERIES PCS add and shed loads in order of assigned priorities. If a low-priority Automatic Transfer Switch (ATS) loses normal power before other high-priority loads, engine-generators start and supply power to the affected ATS. If other ATSs subsequently require backup power, PCS controllers add them according to their previously assigned priorities. This ensures that impacted low-priority loads are quickly transferred to an alternate power source.



With Priority Pass-Along, the loss of normal power at ATS 3 triggers an engine start. If normal power is subsequently lost on other ATSs, they would be added to bus in prioritzed order - in this case, ATSs 1 and 2 together, then ATS 4.

Load Prioritization - A Key to Effective Load Control

ASCO 7000 SERIES PCS products provide unsurpassed power distribution control by managing up to 128 prioritized transfer switches and/or electrically operated circuit breakers. Assigning priorities and sub-priorities to discreet loads in load blocks refines control to maximize generator utilization.

Configure Bus to Maximize Performance

Advanced Bus Segmentation

An extensive range of available bus configurations optimize flexibility, reliability, and performance benefits for every type of facility and application. Here are a few of many possible arrangements.

Single Emergency Bus

A simple cost-effective configuration for managing power sources and loads:

- Synchronize generators as each engine reaches operating speed and voltage
- · Manage connection of loads to the bus according to available generator capacity
- · Shed the lowest priority loads to match available bus or generation capacity
- · A fault on the Emergency Bus will not disrupt the delivery of utility power to loads, and a fault in the utility power pathway will not affect the availability of generators

Main-Tie-Main Using Common Bus

This configuration can connect any remaining power source to any remaining load.



Power

Knowledge

Lincreasing Power

Redundancy



Ring Bus

Unlike linear arrangements, ring bus offers two separate pathways between sources and loads on different bus segments.



Unsurpassed Integration

Custom integration of switching and control elements brings comprehensive monitoring and control capabilities unavailable using other technologies. Through color touchscreen interfaces, operator can manage:

- Synchronizer and Load Share Controllers
- Programmable Logic Controllers
- Power Meters
- · Power Quality Meters



ASCO PCS can provide the following capabilities and benefits:

- · Automatic notifications and alarming through local switchgear interfaces, remote annunciators, and Schneider Electric EcoStruxure
- · Connectivity to building and emergency power management systems via Modbus
- Optional Ethernet-over-Fiber communications for enhanced connectivity

Manual Load Controls

Manual Load Controls maximize operating flexibility by enabling the following features:

Load Shed Bypass/Reset: Manually	•	Ε
re-add previously shed load blocks. To		е
protect generators, any excess loads are		r
automatically re-shed.	•	F
		fr

Hand-Off-Auto: Touchscreen controls for connecting individual automatic transfer switches and circuit breakers to the main bus.

Manual Paralleling: For manually connecting of generators to the main bus if automatic paralleling becomes inoperable.

Generator Control Station: Every generator control section is equipped with manual controls for engine-generator testing, including:

Courtesy of Steven Engineering, Inc - (800) 258-9200 - sales@steveneng.com - www.stevenengineering.com

 Automatic Transfer Switches Circuit Breakers · Protective Relays

· Technician access to detailed diagnostic data

- · User access through remote interfaces to
- important diagnostics and password-protected controls
- Capability to maintain minimum generator loads using one or more load banks
- Optional email and SMS notifications of
- system alarms and events
- Emergency Stop Pushbutton Stop engine-generators quickly using instantly ecognizable controls
- Five-Position Engine Control Switch Select from the following automatic and manual operating modes:
- Automatic Select Normal automatic operation
- · Test Online Test gensets by starting and automatically connecting them to the bus
- Test Offline Test isolated enginegenerators
- · Off-Cool-Down Run engines in cool-down mode for user-defined times
- · Lockout/Reset Immediately stop engines and clear alarms

Enhanced Visualization

The ASCO 7000 SERIES PCS color touchscreens present a user-friendly intuitive interface that can be conveniently located anywhere in a facility. Every ASCO 7000 SERIES PCS can be provisioned with:

- Custom-engineered one-line diagrams that provide dynamic, readable, color-coded circuit elements and power flow schematics
- · Switchgear status indicators for consistent display and instant familiarity
- Touch-linked circuit elements provide rapid access to metering and power information
- · Diagnostics for communication networks, programmable logic controllers, synchronizers, meters, and other devices
- Operator-accessible trend plots for rapid assessment of power and equipment conditions
- Alarm history with up to 500 entries and an event archive of 3 months or more
- Multiple security levels for controls and individual accounts for users



Intelligent Simulation

The available ASCO PCS Simulator provides a digital environment for evaluating procedures and anticipating outcomes. It simulates operation of paralleling gear, transfer switches, circuit breakers, generator controls, switchgear control stations, alarm annunciation, and response. Every Simulator is provisioned with:

- A virtual interface and code that is identical to its real-time system
- Virtual copies of the same hardware and software used on live operator interfaces



Applications

Training

The ASCO PCS Simulator provides reliable and accurate simulation to maximize the benefit of any training exercise. The Simulator can also be used to evaluate operator and equipment performance under multiple operating scenarios, without risk of power system downtime.

Event Sequence Testing

The Simulator can be used to evaluate existing and proposed operating sequences without disrupting live operations. It provides a platform for demonstrating performance improvements for systems.

Predictive Simulation

The Simulator is perfect for evaluating test scenarios including:

- Synchronization failure
- · Utility failure and restoration
- Bus under-frequency
- · Generator failure
- · Loss of bus segment
- Circuit breaker failure
- Bus differential events

 A computer that replicates ASCO 7000 PCS switchgear and connected devices and provides a virtual control console

Efficient Regulatory Reporting

When equipped with a Joint Commission Reporting Package, ASCO 7000 SERIES PCS can generate and distribute documents in ways that make industry and regulatory reporting easy. Generators can be monitored through ASCO Power Metering Units or directly using Modbus protocols. ASCO Critical Power Management Appliances automatically track device performance during outages and test events.

After the last switch has re-transferred to its normal power source, a detailed report is automatically emailed to authorized recipients, which may be used to comply with reporting requirements including NFPA 99, NFPA 110, Joint Commission, CALEA, and CMMS.

Power Knowledge

Line Benefits of Automated Critical Power <u>Reporting</u>

		1	Summary	of Result	:s	POWERQ Power Monitorin	UEST
TEST REPORT	Genera Load Type	tor's engine st Total Transfe Time	r Calculated Transfer Time	d by: ATS 35 I In Emergency (bh.mm:ss)	at 1/13/2016 4:05 Transfer Inhibit Conditions	AM Maximum Passable Time	Result
		10 sec	-	01:20:33		Level 1 (10 sec.)	Pass
	.oad Type	Total Transfe	r Calculated Transfer Time	In Emergency (hhommoss)	Transfer Inhibit Conditions	Maximum Passable Time	Result
	Critical	8 sec	•	01:08:22	•	Level 2 (10 sec.)	Pass
U	Jie Safety Eculoment	8 sec 27 sec		01:10:44		Level 1 (10 sec.)	Pass
	Critical	9 sec		01:09:57		Level 2 (10 sec.)	Pass
Facility Name	Jie Safety	10 sec		01:09:19		Level 1 (10 sec.)	Pass
160 Park Avenue	Critical	9 sec		01.00.11		Level 2 (10 sec.)	Pass
Florham Park, NJ 07932	squpment	284 sec 7 sec	-	01:00:00	Load Shed	Level 3 (30 sec.)	Pass
	Equipment	30 seo		01:08:13		Level 3 (30 sec.)	Pass
	Critical	10 sec	-	01:08:51		Level 2 (10 sec.)	Pass
Generated By : Automated	fechanical	29 500		01:04:52		Level 4 (40 sec.)	Pass
Created : Nov 30, 2018 at 12:55:36 PM	Nechanical Jie Safety	JU SEC		01:10:23		Level 1 (10 sec.)	Pass
Period : Nov 30, 2018 to Nov 30, 2018	Critical	10 sec		01:09:19		Level 2 (10 sec.)	Pass
	iquipment	14 sec	-	01:08:01	•	Level 3 (30 sec.)	Pass
	fechanical	7 sec		01:07:08		Level 4 (40 sec.)	Pass
	echanical Rechanical	7 sec.*		01:07:08		Level 4 (40 sec.)	Pass
	Critical	10 sec	-	01:09:19		Level 2 (10 sec.)	Pass
	lechanical	6 sec		01:07:07		Level 4 (40 sec.)	Pass
Name Location Load Type Power Rating (M)	Current Rating (Amps)	9 AM				Paj	t Bacoct
New Location Load Type Prever Ruling (M) Gan 2 Gan 2 2020 2020 Total Parading System 2020 2020 2020 Total Parading System 7620 October Maintenside Maintenside Maintenside Maintenside Start 01/12/2016 0005.21 AL 60 01/12/2016 0005.21 AL 60 01/12/2016 Maintenside Maintenside	Current Rating (Ampo) 434 m Required Test Time 30 Mins	9 AM . 7016	Transf	er Switch	Summary	Page Power	ower Monitori
New Location Load Type Perent Rating Skyll Can 3 Can Paradra System	Current Rating (Arspa) 4:34 m Required Test Time 30 Mins 30 Mins 30 Mins Min W MK Result hold	A.C.	Transfe	er Switch	Summary (Amps) 400	Page 2010	e 6 of 75 th Bacast OWERI Passable 3 (30 sec.
None London Lond Type Parent Radig Style Gui 13 One Pravaling Style 2000 Total An Tram Fald Or Victoria Style State On Trans Total An Trans Fald Or Victoria Base 011/12/2010 0211 AM Directoria Style Base 011/12/2010 0211 AM Directoria Directoria Base 011/12/2010 0211 AM Directoria Directoria	Current Batting (Anyo) 434 m Riequined Test Time 30 Mms www. WW Result abdd. Pass	9 AM 1014	Transfe Location Dr Parking al Transfer Time	er Switch Calculated ransfer Time	Summary (Angos) 400 In Encogency (hituma.ss)	Page Press Maximum Level Transfer Inhait Conditions	e 6 of 75 stansest OWER(or Monitori Passable 3 (20 sec. Reso
New Location Load Type Perer Mails Street Gan 2 Addelhan Tame DEG Parallelity System 2000 Mails System 2000 Start UNI22016 04/05 06/06 Mile Bool (1990) 05/211 Ad Dirac Dol (1990) 05/211 Ad Dirad <td>Current Rating (Anno) 434 m Required Trest Time 300 Mms menty Abod Pass</td> <td>9 AM JOLA</td> <td>Creation Dr Parting 21 Transfer Time 14 sec</td> <td>er Switch Calculated ansfer Time</td> <td>Summary (Amps) 400 In Emergency (hhuma.ss) 01:08:01 70:08:01</td> <td>Page</td> <td>e 6 of 75 et Bacost. DWERI er Monital Passable 3 (30 sec. Reso Pass passable</td>	Current Rating (Anno) 434 m Required Trest Time 300 Mms menty Abod Pass	9 AM JOLA	Creation Dr Parting 21 Transfer Time 14 sec	er Switch Calculated ansfer Time	Summary (Amps) 400 In Emergency (hhuma.ss) 01:08:01 70:08:01	Page	e 6 of 75 et Bacost. DWERI er Monital Passable 3 (30 sec. Reso Pass passable
None Location Load Type Peret Rating Mol. Out 3 Gene Pranting System 200 State Units of the Time Prantice Maintee State Units of the Time Prantice Maintee Bits of Units of the Time Prantice Maintee Bits of Units of the Time Prantice Maintee Bits of Units of the Time Grade Time State Time	Current Rating (Annex) 434 m Required Test Time 30 Mins many Abdd WK Result hold	9 AM 10156	Constion Dr Parking al Transfer Time 14 sec Transf	er Switch Calculated ansfer Time - www.Calvided In	(Ampo) 400 In Emergency (Mumaco) 01:58:01 01:58:01 ding Graph	Page Page Page Page Page Page Page Page	e 6 of 75 et Bacost WER er Monitol 3 (30 sec. Reso Pas Pas
Nome London Load Type Power budge Digg Mare ComParading System 2000 2000 2000 Total An Time Total Concept 2000 200	Current Rating (Ango) 454 In Required Text Time 30 Mrs 30 Mrs WW Pass	9 AM 	Transfe Location Dr Parting al Transfer Time 14 sec Transf	er Switch Calculated ansfer Time - - wars. Calculated to an of the table	Summary 400 In Encouncy (Ampso.) 01:08:01 01:08:01	Page Page Page Page Page Page Page Page	pe 6 of 75 stationet. OWER(or Monitori Passable 3 (30 sec. Reso Pass Pass scortgrad to
Total Lond m Lond Type Person Holding Grad One-Parading System 502 00 502 00 Total Bio Theor Edd Doration 602 00 502 00 Biol Christophild Stage 01/12/201 00:21 144 602 500 5000 Biol Christophild Stage 01/12/201 00:21 144 602 500 5000 Biol Christophild Stage 01/12/201 00:21 144 602 500 5000 Biol Christophild Stage 01/12/201 00:21 144 603 504 5000 Biol Christophild Stage 01/12/201 00:10 6000 500 5000 5000 Biol Christophild Stage 01/12/201 00:10 6000 500 5000 5000 5000 Biol Christophild Stage 01/12/201 00:10 6000 500 6000 500 5000 5000 5000 5000 5000 500 5000 5000 500 5000 500 5000 500 5000 500 5000 500 5000 500 5000 500 5000 500 5000 500 5000 500 5000 500 5000 500 5000 500 5000 500 5000 500 5000 500 5000 500 5000 500	Connect Rang (Ango) 334 an Bogkard Tet Time 30 Mms with Pass WW Pass	9 AM JOLK	Coaston Dr Paning Di Fransfer 14 seo Transf	er Switch	Summary (Ampro) 400 In Emergency (Mulmus.23) 01:58:01	Page Power P	e 6 of 75 th Boost WERI or Monitoria Passable 3 (30 sec. Rans Pas source in
No. Location Location Annu House Location Location <thlocation< th=""> Location <th< td=""><td>Connect Burney 4-54 Requered Test Time 30 Mms MMT MMT MMT Pass </td><td>9 AM 3014</td><td>I Transfe Dr Paring 21 Transfer 14 seo Transfer Transfer Transfer Transfer</td><td>er Switch</td><td>Summary 400 400 In Energency phanesof or second or secon</td><td>Page Networks Page Networks Pa</td><td>e 6 of 75 stallacout. DWERI Passable 3 (30 sec. Reso Pass particular</td></th<></thlocation<>	Connect Burney 4-54 Requered Test Time 30 Mms MMT MMT MMT Pass 	9 AM 3014	I Transfe Dr Paring 21 Transfer 14 seo Transfer Transfer Transfer Transfer	er Switch	Summary 400 400 In Energency phanesof or second or secon	Page Networks Pa	e 6 of 75 stallacout. DWERI Passable 3 (30 sec. Reso Pass particular
No. Losdim Losd yr Perer Mall BMD One 3 One Parallellis Stem 200 Sac U VIS2016 00 52:11 AI Dial Row BMD 102.00 Bac U VIS2016 00 52:11 AI Dial Row BMD Dial Row BMD Bac U VIS2016 00 52:11 AI Dial Row BMD Dial Row BMD Bac U VIS2016 01 52:11 AI Dial Row BMD Dial Row BMD Bac U VIS2016 01 52:11 AI Dial Row BMD Dial Row BMD Bac U VIS2016 01 52:11 AI Dial Row BMD Dial Row BMD Bac U VIS2016 01 52:11 AI Dial Row BMD Dial Row BMD Bac U VIS2016 01 52:11 AI Dial Row BMD Dial Row BMD Bac U VIS2016 01 52:11 AI Dial Row BMD Dial Row BMD Bac U VIS2016 01 52:11 AI Dial Row BMD Dial Row BMD Bac U VIS2016 01 52:11 AI Dial Row BMD Dial Row BMD Bac U VIS2016 01 52:11 AI Dial Row BMD Dial Row BMD Bac U VIS2016 01 52:11 AI Dial Row BMD Dial Row BMD Bac U VIS2016 01 52:11 AI Dial Row BMD Dial Row BMD Bac U VIS2016 01 52:11 AI Dial Row BMD Dial Row BMD <td>Correct Barry -54 Request Test Too So Mis WW Pass</td> <td>9 AM 3 3334</td> <td>Location Dr Parking Chi Fransker Tone Tone Tone Transf</td> <td>er Switch</td> <td>Summary 4000 400 bit Ecceptor (http://doi.org/10.0000 01.000000 01.00000000</td> <td>Page Page Page Page Page Page Page Page</td> <td>pe 6 of 75 Alexandric DOWERI Passable Reserved R</td>	Correct Barry -54 Request Test Too So Mis WW Pass	9 AM 3 3334	Location Dr Parking Chi Fransker Tone Tone Tone Transf	er Switch	Summary 4000 400 bit Ecceptor (http://doi.org/10.0000 01.000000 01.00000000	Page Page Page Page Page Page Page Page	pe 6 of 75 Alexandric DOWERI Passable Reserved R
Image: Second	Compart Rating (Area) C4.4 a Regard Test Tax Solids W Pros 		I Transfe Dr Parting 21 Frankfer 14 soo 21 Stock In Advances Transfer 14 soo	er Switch	Summary 400 900 915801 915801 915801 915801	Pare Pres	pe 6 of 73 at a lancet. DVWER Passable Pass Pass Pass Pass
Total Land mp Land Type Part Holds 0x1 One Parading System 2020 Total Ban Tame Edd Da Yould 2020 Total Ban Tame Other State 2020 Total Ban Tame Edd Da Yould 2020 Total Ban Tame Other State 2020 Total Ban Tame Dano 2020 <td>Comput gang Col Sol Sol Soles Soles W Pas</td> <td>2 Total</td> <td> Transfe De Paring Transfer Yes Viso Transfer Viso Transfer Viso</td> <td>er Switch</td> <td>Summary 400 015801 015801 015801</td> <td>Pare Press</td> <td>pe 6 of 75 st Barnott. DWERP Passes Monitori Passes Monitori Passes Passes Passes Passes</td>	Comput gang Col Sol Sol Soles Soles W Pas	2 Total	Transfe De Paring Transfer Yes Viso Transfer Viso Transfer Viso	er Switch	Summary 400 015801 015801 015801	Pare Press	pe 6 of 75 st Barnott. DWERP Passes Monitori Passes Monitori Passes Passes Passes Passes
Total Land Total Annu Aller State State Gan Cale Paradity System State State State State State State Total Run Total State State Stat	Compart Adding 0.4 CA Regulard Ent Time Strate Strate Mining M Result Mining M Result Mining M Result Mining M Result		Transfe Dr Paring Tenes Vi Seo Transf Vi Seo	er Switch	Summary 400 11:8001 10:80000 10:8001 10:8001 10:8001 10:8001 10:8001 10:8001 10:8001 1	Page Page Page Page Page Page Page Page	p 6 of 75 st Baroot
Image: constraint of the second sec	Commerce during (Menon)		I Transfer	er Switch	Summary Corport States Stat		p 6 of 75 th Resolution
The transmission of the tr	Comment Rading CA CA In Request CENT Fire SMME W Pes VF December VF December		I Transfer	er Switch	August 400 400 The Encarsol 015001 0150000000000	Part Provide the second	pa 6 of 73 at all accord. DWERE THE Monitorial Control of the Control of the Co
Total Land main Land Type Part Holds 0x1 Our Practing System 2000 Total Ban Tare Edd Dar Zold 2000 Total Ban Tare Otrace 2000 Totar Otrace 2000 2000 Total Ban Tare Otrace 2000 2000 Total Ban Tare 2000 2000 2000 2000 Total Ban Tare 2000 2000 2000 2000 2000 <tr< td=""><td>Comvet Barry Co.4 Co.4 Noncontrol Control Noncon Noncontrol Noncon</td><td></td><td>Location Dr Parting M Franking T 14 see Team Table Statement Team Table Statement M Statement M Statement</td><td>er Switch</td><td></td><td>Page Page Page Page Page Page Page Page</td><td>pe 6 of 73 at all according to the second se</td></tr<>	Comvet Barry Co.4 Co.4 Noncontrol Control Noncon Noncontrol Noncon		Location Dr Parting M Franking T 14 see Team Table Statement Team Table Statement M Statement M Statement	er Switch		Page Page Page Page Page Page Page Page	pe 6 of 73 at all according to the second se
Tex Land /m Land /m Period by Experiment Bit /m Experiment	Connect Bulling All All a Request CFLT Tare 30 Mars many Mars Result 00 Pros 100 Pros 1	2 AAI 	Location Dr Parting Mi Franking Mi Franking Mi Stanking Mi Stankin	ar Switch	Summary	Page 2014	pa 6 of 75 at 32mont. Prost Monitoria Prost Monitoria
The transmission of the second	Commerce Rading Collars Collars Solves Solves W Pers	2 AAI an Tel an Tel	Location Dr Paring Transf 14 are Transf Transf Transf Stations Sta	er Switch	Summary 400 01001 01000 01000 01000 0000 0000 0000 0000 0000 0000 0000 0000	Page Page Page Page Page Page Page Page	pe 6 of 75 at Barowski Statement Passis Xdenibad Passis Xdenibad Passis Xdenibad Passis Xdenibad Passis Pas
Total Landam Land Type Person hadde Out Our Parading System 2000 Total Room Edd Room 2000 Total Room Edd Room 2000 Total Room Edd Room 2000 Total Room 2000 2000 2000 Total Room 2000 2000 2000 2000 Total Room 2000 2000 2000 2000 2000 2000 Total Room 2000<	Commer Expine Color Color Solution Solution W Pos		Location De Paratra Tare Marine Al Seator Sector De Januario Contra Contra Contra Contra Contra Contra Contra Contra Contra Contra Cont	er Switch	Summary 4000000 905001 9150001 915	Figure 1 - Construction - Constructi	pe 6 of 75 at January Passes Monitoria Passes
Totol Last Type New Holds Last Type Last Type <thlast th="" type<=""> <thlast th="" type<=""></thlast>Last Type<td>Connect Stang All a Regreet Test Test So Mar many or Pres </td><td>9 AM and Television and Tele</td><td>I Transfer T</td><td>er Switch</td><td></td><td></td><td>Provide Contract of Contract o</td></thlast>	Connect Stang All a Regreet Test Test So Mar many or Pres 	9 AM and Television and Tele	I Transfer T	er Switch			Provide Contract of Contract o
Transformed and the second sec	Commerce during Color Color Solor	9 AM a b b b b b b b b b b b b b b b b b b b	Transfer Dr have Transfer Tr	er Switch	Automate and a second and a sec		Plant Market
Transfer for 1. NEW BY NA 200 Transfer for 1. NEW BY NA 200	Comment Rading Col 4 Register Cent Ten Shifts Million Cent Ten Shifts Cent	B AM	I Transfer Dr Party Trees to a trees to a tr	ar Switch	Summary According to the second according to		Pask Market

7000 SERIES Models with System Voltage	600 V Max.	5kV/15kV (consult factory for higher)
Modes of Operation		
Isolated Bus (Open Transition)	Yes	Yes
Generator Soft Load/Unload	Yes	Yes
Utility Tie (Momentary Closed Transition)	Yes	Yes
Utility Tie (Soft Load/Unload)	Yes	Yes
Generators	32	32
Construction		
Main Bus Amp Size Available	Up to 10,000 A	Up to 3000 A
Switchgear Standard	UL 1558 (Standard)	ANSI/IEEE C37.20.2
Bus Bracing level kA		
Arc Resistant/Arc Protection Relaying	Optional	Optional
Enclosure		Indoor/Outdoor/Outdoor Sheltered Aisle
Circuit Broakers		
Generator Paralleling Breakers	1 or 2 per cubicle	1 per cubicle
Maximum Generator Breaker Frame Size	3200 A (2)	
	5000 A (1)	op to 2000 A
Tie and/or Utility Circuit Breaker Available	Optional	Optional
Master Controls		
Master Controls	Integrated Segregated	Integrated Segregated
Master Controls Touch Screen	24" Std. / Up to 42"	24" Std. / Up to 42"
Redundant Touch Screens	Optional	Optional
Engine-Generator Info Screen	Yes	Yes
NFPA 110 Generator Monitoring	Yes	Yes
Master PLC	Yes	Yes
Redundant Master PLC	Standard, unless otherwise specified	Standard, unless otherwise specified
Redundant Master I/O	Optional	Optional
Hardwired Manual Paralleling	Standard	Standard
Bus Load Optimization	Standard	Standard
Generator Load Demand	Standard	Standard
Max. Number of ATSs for Load Control (MO DCB)	32 Std. / Up to 128	32 Std. / Up to 128
Max. Number of ATSs for Load Control (EO DCB)	32 Std. / Up to 128	32 Std. / Up to 128
Main Bus - Maximum Segments	8	8
Generator Controls Sections		
Generator Controls	Integrated Segregated	Integrated Segregated
Generator Synchronizer Type	Digital	Digital
Generator PLC	Yes	Yes
Hardwired Backup Controls	Standard	Standard
Generator Controls Touchscreen	Optional	Optional
Distribution Circuit Breakers		
Manually Operated Distribution Circuit Breakers	Optional	N/A
Electrically Operated Distribution Circuit Breakers	Optional	Standard
Remote Monitoring		
Remote Annunciator Panel, LED Type	Optional	Optional
Remote Annunciator Panel, Touchscreen Type	Optional	Optional
42" Color Touchscreen	Optional	Optional
PowerQuest Remote Desktop Monitoring	Optional	Optional
NFPA Test Report Package	Optional	Optional
JC Reporting Package	Optional	Optional
Simulator		
Simulator for Testing and Training	Optional	Optional

7000 SERIES Features and Options

Life Is On Schneider

ASCO Power Technologies - Global Headquarters 160 Park Avenue Florham Park, NJ 07932 Tel: 800 800 ASCO

www.ascopower.com customercare@ascopower.com

© 2022 ASCO Power Technologies. All Rights Reserved. Life Is On Schneider Electric is a trademark and the property of Schneider Electric SE, its subsidiaries and affiliated companies. Publication 2023 R2. Printed in the U.S.A.